PRFL14 GRID FIXTURE INSTALLATION

DISCONNECT POWER BEFORE INSTALLATION OR RISK OF ELECTRICAL SHOCK. SERVICING.



QUALIFIED ELECTRICIAN IN NATIONAL ELECTRIC CODES **ACCORDANCE TO LOCAL &** TO BE INSTALLED BY A




FORMENTIONED WARNINGS **INSTRUCTIONS &** COULD VOID PRODUCT FAILURE TO COMPLY TO





CEILING TO BE PROPERLY REINFORCED TO SUPPORT WEIGHT OF THE FIXTURE.


(BY OTHERS) TIE WIRES

4









2. DROP NEXT FIXTURE INTO APPROPRIATE SIZED GRID OPENING FROM ABOVE GRID. 1. DROP FIRST FIXTURE INTO APPROPRIATE SIZED GRID REFER TO JOB DRAWINGS FOR JOB SPECIFIC WIRING PLATE OF FIXTURE. INSTALL POWER FEED WITH 5. CONNECT POWER FEED CONDUCTORS TO ACCESS FIXTURE AS REQUIRED BY LOCAL ELECTRICAL CODE APPROPRIATE STRAIN RELIEF TO SECURE CORD IN

BRACKET TO FIXTURE.

OPENING FROM ABOVE GRID. INSTALL TIE WIRE

6. INSTALLATION IS COMPLETE

FIXTURE WIRES

ACCESS PLATE

3. JOIN FIXTURES WITH SUPPLIED HARDWARE AND JOINING HARDWARE. CONTINUE INSTALLING AND CONNECT WIRE HARNESSES. DO NOT OVER TIGHTEN JOINING FIXTURES UNTIL ROW IS COMPLETE.

END TO APPROPRIATE STRUCTURE TO SUPPORT 4. INSTALL TIE WIRE TO FIXTURE AND SECURE OTHER

SPECIFIC, CONSULT SHOP DRAWINGS BEFORE CONSTRUCTING ROWS. STANDARD OPTIONS/SIZES SHOWN, OTHER OPTIONS AVAILABLE WITH SIMILAIR INSTALLATION. BE SURE TO UNDERSTAND ALL PROCEDURES PRIOR TO INSTALLATION. IMPORTANT: THE NATIONAL ELECTRIC CODE REQUIRES THAT ANY FIXTURE IN EXCESS OF 50 POUNDS MUST BE INDEPENDENTLY SUPPORTED OF THE OUTLET BOX. DAY-O-LITE IS NOT RESPONSIBLE FOR INADEQUATE REINFORCEMENT OF STRUCTURAL SUPPORT SYSTEMS. DAY-O-LITE RESERVES THE RIGHT TO MAKE MUST BE INSTALLED BY A QUALIFIED ELECTRICIAN. DISCONNECT POWER DURING INSTALLATION/SERVICING. ROW CONFIGURATION IS JOB THE PROPERTY OF DAY-O-LITE AND THE INFORMATION IT CONTAINS MAY NOT BE USED WITHOUT WRITTEN CONSENT OF DAY-O-LITE. ANY MECHANICAL OR MATERIAL CHANGES TO THE FIXTURES WHICH DO NOT AFFECT THE APPEARANCE OR PERFORMANCE. THIS PRINT IS

CONTACT INFORMATION: PRFL14-G---

SHEET 1 OF 1

4/29/2020 ISSUED ON 970083A0

WWW http://www.dayolite.com E-mail: sales@dayolite.com Tel. (401) 467-8232 Fax. (401) 941-2960 126 Chestnut Street, Warwick, RI 02888

Lighting Without Limits