



WPPL-4-6 GRID FIXTURE INSTALLATION



INSTALLATION OVERVIEW







RISK OF ELECTRICAL SHOCK. DISCONNECT POWER BEFORE INSTALLATION OR SERVICING.

DO NOT CONSTRUCT ROW ON FLOOR & LIFT TO CEILING.

KEEP ALL PROTECTIVE FILMS ON APPLICABLE SURFACES UNTIL FIXTURES ARE INSTALLED.

MUST INSTALL PRIOR TO CEILING.

TO BE INSTALLED BY A QUALIFIED ELECTRICIAN IN ACCORDANCE TO LOCAL & NATIONAL ELECTRIC CODES.



INSTALLATION INSTRUCTIONS

1. INSTALL WALL BRACKET AS SHOWN, LEFT TO RIGHT, ACCORDING TO DRAWINGS PROVIDED WITH JOB. WALL BRACKETS ARE SHIPPED SEPERATE FROM FIXTURE. IF PROVIDED, CUT TELESOPING FIXTURE WALL RAIL TO FIT. CORNER WALL RAILS ARE SHIPPED STRAIGHT AND SHOULD BE BENT TO MATCH CORNER.
2. INSTALL TRIM TO FIXTURE HOUSINGS USING #8 SHEET METAL SCREWS PROVIDED. TRIMS AND SCREWS ARE SHIPPED SEPERATE FORM FIXTURE.
3. PLACE THE FIRST FIXTURE OVER THE THE WALL BRACKET. BEND SAFETY TABS OF WALL RAIL OVER FIXTURE. SECURE OTHER SIDE OF FIXTURE WITH TIE WIRE
4. INSTALL NEXT FIXTURE. INSTALL JOINT ALIGNER AND TOP ALIGNER. SECURE FIXTURES TOGETHER USING (4) SCREWS IN JOINT ALIGNER AND SECURING TOP ALIGNER WITH SUPPLIED NUTS.
5. SECURE THE GRID CLIP TO THE FRONT TRIM USING SCREWS PROVIDED, AND SECURE TO CEILING WITH THE GRID CLIP
6. ATTACH THE END CAP TO THE FRONT SHIELD AT THE BEGINNING AND END OF ROW
7. INSTALL LENS

NOTE: SEE PAGE 2 OF 2 FOR ADJUSTABLE TELESOPIC UNIT

MUST BE INSTALLED BY A QUALIFIED ELECTRICIAN. DISCONNECT POWER DURING INSTALLATION/SERVICING. ROW CONFIGURATION IS JOB SPECIFIC, CONSULT SHOP DRAWINGS BEFORE CONSTRUCTING ROWS. STANDARD OPTIONS/SIZES SHOWN, OTHER OPTIONS AVAILABLE WITH SIMILAIR INSTALLATION. BE SURE TO UNDERSTAND ALL PROCEDURES PRIOR TO INSTALLATION. IMPORTANT; THE NATIONAL ELECTRIC CODE REQUIRES THAT ANY FIXTURE IN EXCESS OF 50 POUNDS MUST BE INDEPENDENTLY SUPPORTED OF THE OUTLET BOX. DAY-O-LITE IS NOT RESPONSIBLE FOR INADEQUATE REINFORCEMENT OF STRUCTURAL SUPPORT SYSTEMS. DAY-O-LITE RESERVES THE RIGHT TO MAKE ANY MECHANICAL OR MATERIAL CHANGES TO THE FIXTURES WHICH DO NOT AFFECT THE APPEARANCE OR PERFORMANCE. THIS PRINT IS THE PROPERTY OF DAY-O-LITE AND THE INFORMATION IT CONTAINS MAY NOT BE USED WITHOUT WRITTEN CONSENT OF DAY-O-LITE.

MODEL NO.:
WPPL-4-6-G----

CONTACT INFORMATION:
126 Chestnut Street, Warwick, RI 02888
Tel. (401) 467-8232 | Fax. (401) 941-2960
E-mail: sales@dayolite.com
WWW: http://www.dayolite.com



PAGE:
SHEET 1 OF 2



PART NUMBER:
970087A1

ISSUED ON:
7/28/2020

TELESCOPIC FIXTURE INSTRUCTIONS









INSTALLATION INSTRUCTIONS

- 1. REMOVE TOP PLATE AND TRIM FROM TELE FIXTURE. CUT WALL BRACKET, TOP PLATE AND TRIM TO REQUIRED LENGTH TO COMPLETE FIXTURE RUN. SECURE WALL BRACKET TO WALL.
- 2. ADJUST TELE HOUSING TO REQUIRED LENGTH TO COMPLETE FIXTURE RUN. ADJUST LED TRAY TO REQUIRED LENGTH TO FILL FIXTURE.
- 3. RE-INSTALL FRONT TRIM AND TOP PLATE TO FIXTURE USING SCREWS REMOVED IN STEP 1
- 4. INSTALL FIXTURE ACCORDING TO INSTRUCTIONS ON PAGE 1



RISK OF ELECTRICAL SHOCK. DISCONNECT POWER BEFORE INSTALLATION OR SERVICING.

 <p>FAILURE TO COMPLY TO INSTRUCTIONS & FORMENTIONED WARNINGS COULD VOID PRODUCT WARRANTY</p>	 <p>MUST INSTALL PRIOR TO CEILING.</p>	 <p>TO BE INSTALLED BY A QUALIFIED ELECTRICIAN IN ACCORDANCE TO LOCAL & NATIONAL ELECTRIC CODES.</p>
 <p>DAY-O-LITE ASSUMES NO RESPONSIBILITIES FOR CLAIMS FOUNDED FROM IMPROPER INSTALLATION OR HANDLING.</p>	 <p>DO NOT CONSTRUCT ROW ON FLOOR & LIFT TO CEILING.</p>	 <p>KEEP ALL PROTECTIVE FILMS ON APPLICABLE SURFACES UNTIL FIXTURES ARE INSTALLED.</p>

MUST BE INSTALLED BY A QUALIFIED ELECTRICIAN. DISCONNECT POWER DURING INSTALLATION/SERVICING. ROW CONFIGURATION IS JOB SPECIFIC, CONSULT SHOP DRAWINGS BEFORE CONSTRUCTING ROWS. STANDARD OPTIONS/SIZES SHOWN, OTHER OPTIONS AVAILABLE WITH SIMILAIR INSTALLATION. BE SURE TO UNDERSTAND ALL PROCEDURES PRIOR TO INSTALLATION. IMPORTANT: THE NATIONAL ELECTRIC CODE REQUIRES THAT ANY FIXTURE IN EXCESS OF 50 POUNDS MUST BE INDEPENDENTLY SUPPORTED OF THE OUTLET BOX. DAY-O-LITE IS NOT RESPONSIBLE FOR INADEQUATE REINFORCEMENT OF STRUCTURAL SUPPORT SYSTEMS. DAY-O-LITE RESERVES THE RIGHT TO MAKE ANY MECHANICAL OR MATERIAL CHANGES TO THE FIXTURES WHICH DO NOT AFFECT THE APPEARANCE OR PERFORMANCE. THIS PRINT IS THE PROPERTY OF DAY-O-LITE AND THE INFORMATION IT CONTAINS MAY NOT BE USED WITHOUT WRITTEN CONSENT OF DAY-O-LITE.

MODEL NO.:
WPPL-4-6-G----

CONTACT INFORMATION:
126 Chestnut Street, Warwick, RI 02888
Tel. (401) 467-8232 | Fax. (401) 941-2960
E-mail: sales@dayolite.com
WWW: http://www.dayolite.com

PAGE:
SHEET 1 OF 2

PART NUMBER:
970087A1
ISSUED ON:
7/28/2020

